

<b>Heat pump model</b>	<b>Master Therm</b>	<b>BA45I-1</b>
------------------------	---------------------	----------------

Heat pump type	Air/Water
Supplementary heater	Yes
Heat pump combination heater	No

Reference heating season		<b>Average</b>		
Reference water temperature		<b>LOW, 35°C</b>		
Full load heating		<b>Prated [kW]</b>	<b>13.37</b>	
Seasonal efficiency		<b><math>\eta_s</math> [%]</b>	<b>175</b>	<b>A+++</b>
Annual electricity consumption		<b><math>Q_{HE}</math> [kWh]</b>	<b>6195</b>	
<b>Average 35°C</b>	Outdoor heat exchanger	Declared capacity	COP at part load	Degradation Coefficient
	Outdoor air			
	$T_j$ [°C]	Pdh [kW]	COPd (-)	Cdh (-)
A	-7	11.83	2.77	0.900
B	2	7.91	4.17	0.900
C	7	4.88	6.44	0.900
D	12	5.73	7.93	0.967
TOL (E)	-10	10.96	2.32	0.900
Tbivalent (F)	-7	11.83	2.77	0.900

Reference heating season		<b>Average</b>		
Reference water temperature		<b>High, 55°C</b>		
Full load heating		<b>Prated [kW]</b>	<b>12.05</b>	
Seasonal efficiency		<b><math>\eta_s</math> [%]</b>	<b>136</b>	<b>A++</b>
Annual electricity consumption		<b><math>Q_{HE}</math> [kWh]</b>	<b>7166</b>	
<b>Average 55°C</b>	Outdoor heat exchanger	Declared capacity	COP at part load	Degradation Coefficient
	Outdoor air			
	$T_j$ [°C]	Pdh [kW]	COPd (-)	Cdh (-)
A	-7	10.66	2.10	0.900
B	2	6.82	3.28	0.900
C	7	4.38	5.00	0.900
D	12	4.83	6.13	0.970
TOL (E)	-10	9.57	1.77	0.900
Tbivalent (F)	-7	10.66	2.10	0.900

Reference heating season		<b>Warmer</b>		
Reference water temperature		<b>Low, 35°C</b>		
Full load heating		<b>Prated [kW]</b>	<b>15.78</b>	
Seasonal efficiency		<b><math>\eta_s</math> [%]</b>	<b>251</b>	
Annual electricity consumption		<b><math>Q_{HE}</math> [kWh]</b>	<b>3326</b>	
<b>Warmer 35°C</b>	Outdoor heat exchanger	Declared capacity	COP at part load	Degradation Coefficient
	Outdoor air			
	$T_j$ [°C]	Pdh [kW]	COPd (-)	Cdh (-)
B	2	15.78	3.03	0.900
C	7	9.77	5.50	0.900
D	12	5.09	8.20	0.961
TOL (E)	2	15.78	3.03	0.900
Tbivalent (F)	2	15.78	3.03	0.900

<b>Heat pump model</b>	<b>Master Therm</b>	<b>BA45I-1</b>
------------------------	---------------------	----------------

Reference heating season		<b>Warmer</b>		
Reference water temperature		<b>High, 55°C</b>		
Full load heating		<b>Prated [kW]</b>	<b>13.11</b>	
Seasonal efficiency		<b><math>\eta_s</math> [%]</b>	<b>172</b>	
Annual electricity consumption		<b><math>Q_{HE}</math> [kWh]</b>	<b>3992</b>	
<b>Warmer 55°C</b>	Outdoor heat exchanger	Declared capacity	COP at part load	Degradation Coefficient
	Outdoor air			
	$T_j$ [°C]	Pdh [kW]	COPd (-)	Cdh (-)
B	2	13.11	2.14	0.900
C	7	8.70	3.66	0.900
D	12	6.40	5.94	0.978
TOL (E)	2	13.11	2.14	0.900
Tbivalent (F)	2	13.11	2.14	0.900

Reference heating season		<b>Colder</b>		
Reference water temperature		<b>Low, 35°C</b>		
Full load heating		<b>Prated [kW]</b>	<b>19.79</b>	
Seasonal efficiency		<b><math>\eta_s</math> [%]</b>	<b>130</b>	
Annual electricity consumption		<b><math>Q_{HE}</math> [kWh]</b>	<b>14639</b>	
<b>Colder 35°C</b>	Outdoor heat exchanger	Declared capacity	COP at part load	Degradation Coefficient
	Outdoor air			
	$T_j$ [°C]	Pdh [kW]	COPd (-)	Cdh (-)
A	-7	11.98	2.61	0.900
B	2	7.22	4.62	0.900
C	7	5.76	6.63	0.972
D	12	6.74	7.93	0.972
TOL (E)	-22	8.20	1.97	0.900
Tbivalent (F)	-7	11.98	2.61	0.900
G	-15	9.47	2.18	0.900

Reference heating season		<b>Colder</b>		
Reference water temperature		<b>High, 55°C</b>		
Full load heating		<b>Prated [kW]</b>	<b>19.18</b>	
Seasonal efficiency		<b><math>\eta_s</math> [%]</b>	<b>108</b>	
Annual electricity consumption		<b><math>Q_{HE}</math> [kWh]</b>	<b>17082</b>	
<b>Colder 55°C</b>	Outdoor heat exchanger	Declared capacity	COP at part load	Degradation Coefficient
	Outdoor air			
	$T_j$ [°C]	Pdh [kW]	COPd (-)	Cdh (-)
A	-7	11.61	2.09	0.900
B	2	6.66	3.72	0.900
C	7	5.56	5.43	0.977
D	12	6.52	6.52	0.976
TOL (E)	-22	7.65	1.68	0.900
Tbivalent (F)	-7	11.61	2.09	0.900
G	-15	8.95	1.77	0.900

<b>Heat pump model</b>	<b>Master Therm</b>	<b>BA45I-1</b>
------------------------	---------------------	----------------

Power consumption in modes other than "active mode"		
Off mode	$P_{OFF}$ [kW]	0.026
Thermostat off mode	$P_{TO}$ [kW]	0.024
Standby mode	$P_{SB}$ [kW]	0.026
Crankcaseheater mode	$P_{CK}$ [kW]	-

Supplementary heater capacity	$P_{SUP}$ [kW]	7.5(+7.5)
Supplementary heater type	[-]	electricity

Capacity control		Variable
Sound power level Indoor	$L_{WA}$ [dBA]	-
Sound power level Outdoor	$L_{WA}$ [dBA]	62
Rated airflow	[m <sup>3</sup> /h]	max.8000

Temperature controller		
Type	Carel pCO5/pCO5+/uPC, Master Therm custom SW	
Class	II	
Contribution	%	2.0

Temperature controller + Room Terminal		
Type	Carel pCO5/pCO5+/uPC + pAD, Master Therm custom SW	
Class	VI	
Contribution	%	4.0

<b>Heat pump model</b>	<b>Master Therm</b>	<b>BA45I-1</b>
------------------------	---------------------	----------------

<b>Information sheet</b>			
Temperature application		Low, 35°C	High, 55°C
Space heating energy efficiency class, Average climate	-	A+++	A++
Nominal heating capacity Pdesign, Average climate	kW	13	12
Space heating seasonal efficiency, Average climate	%	175	136
Space heating annual electricity consumption, Average cl.	kWh	6195	7166

Nominal heating capacity Pdesign, Colder climate	kW	20	19
Space heating seasonal efficiency, Colder climate	%	130	108
Space heating annual electricity consumption, Colder cl.	kWh	14639	17082

Nominal heating capacity Pdesign, Warmer climate	kW	16	13
Space heating seasonal efficiency, Warmer climate	%	251	172
Space heating annual electricity consumption, Warmer cl.	kWh	3326	3992

Sound power level Lwa Outdoor	dBA	62
-------------------------------	-----	----

<b>Information sheet for energy efficiency Set with Temperature controller</b>			
Temperature application		Low, 35°C	High, 55°C
Controller Carel pCO5/pCO5+/uPC, Class	-	II	II
Controller Carel pCO5/pCO5+/uPC, Contribution	%	2.0	2.0
Set Space heating seasonal efficiency, Average climate	%	177	138
Set Space heating energy efficiency class, Average climate	-	A+++	A++
Set Space heating seasonal efficiency, Colder climate	%	132	110
Set Space heating seasonal efficiency, Warmer climate	%	253	174

<b>Information sheet for energy efficiency Set with Temperature controller + Room Terminal</b>			
Temperature application		Low, 35°C	High, 55°C
Controller Carel pCO5/pCO5+/uPC + pAD, Class	-	VI	VI
Controller Carel pCO5/pCO5+/uPC, +pAD, Contribution	%	4.0	4.0
Set Space heating seasonal efficiency, Average climate	%	179	140
Set Space heating energy efficiency class, Average climate	-	A+++	A++
Set Space heating seasonal efficiency, Colder climate	%	134	112
Set Space heating seasonal efficiency, Warmer climate	%	255	176